

County Permit No. _____

WELL LOG AND DRILLING REPORT

156

ORIGINAL

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBINGState of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

549795

COUNTY WAYNE TOWNSHIP CHIPPEWA SECTION OF TOWNSHIP _____OWNER LARRY FRETWELL ADDRESS RITTMAN, OHIOLOCATION OF PROPERTY 12570 DOYLESTOWN RD.**CONSTRUCTION DETAILS****BAILING OR PUMPING TEST**

(Specify one by circling)

Casing diameter 5" Length of casing 27
 Type of screen NONE Length of screen —
 Type of pump 1/2 HP SUB
 Capacity of pump 10 GPM
 Depth of pump setting 90'
 Date of completion _____

Test rate 30+ gpm Duration of test 2 hrs
 Drawdown 0' ft Date 1/15/80
 Static level (depth to water) 60' ft
 Quality (clear, cloudy, taste, odor) CLEAR
 Pump installed by DRILLER

WELL LOG***SKETCH SHOWING LOCATION**Formations: sandstone, shale,
limestone, gravel, clay

From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.CLAY, YELLOW

0 ft

17' ft

ROCK, GRAY SHALE (SANDY)

17'

22'

ROCK, GRAY SHALE (HARD)

22'

94'

ROCK, GRAY SAND

94'

115'

WATER AT

94'

W

STREET

N

WELL

E

CO RD 70

DOYLESTOWN RD.

S

DRILLING FIRM GENE'S WATER SERVICE INC. DATE 1/15/80ADDRESS 1175 REIMER RD.
WADSWORTH, OHIO SIGNED Eugene J. J.

*If additional space is needed to complete well log, use next consecutive numbered form.

32