

NO CARBON PAPER
NECESSARY-
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

550460

COUNTY Marion TOWNSHIP Greencamp SECTION OF TOWNSHIP _____
OWNER Robert Clunk ADDRESS 4054 S.W. - Greencamp Rd. Marion, Oh.
LOCATION OF PROPERTY same as above 43302

CONSTRUCTION DETAILS		BAILING OR PUMPING TEST (specify one by circling)	
Casing diameter <u>5"</u>	Length of casing <u>47'</u>	Test rate <u>12</u> gpm	Duration of test <u>2</u> hrs
Type of screen _____	Length of screen _____	Drawdown <u>5</u> ft	Date <u>1/17/79</u>
Type of pump _____		Static level (depth to water) <u>20'</u>	ft
Capacity of pump _____		Quality (clear, cloudy, taste, odor) <u>good</u>	
Depth of pump setting _____			
Date of completion <u>1/12/79</u>		Pump installed by _____	

[illegible]

DRILLING FIRM Amel Green Well Drilling
ADDRESS 712 O'Donnell St. Upper Sandusky, OH.

DATE 2/6/79
SIGNED James K. Green