

County Permit No. _____

WELL LOG AND DRILLING REPORT

ORIGINAL

126

551651

✓

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBINGState of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224COUNTY COSHOCTON TOWNSHIP ADAMS SECTION OF TOWNSHIP _____OWNER JACK FLYNN ADDRESS RR #1 FRESNO OHIOLOCATION OF PROPERTY (TWP ROAD #249) 3 MILES NORTH EAST OF
STATE ROUTE 36**CONSTRUCTION DETAILS****BAILING OR PUMPING TEST**

(specify one by circling)

Casing diameter 5" Length of casing 85' 9" Test rate 10 gpm Duration of test 2 hrs
 Type of screen NONE Length of screen _____ Drawdown 1 ft Date 5-29-80
 Type of pump _____ Static level (depth to water) 36 ft
 Capacity of pump _____ Quality (clear, cloudy, taste, odor) CLEAR
 Depth of pump setting _____ Pump installed by OWNER
 Date of completion 5-24-80

WELL LOG***SKETCH SHOWING LOCATION**Formations: sandstone, shale,
limestone, gravel, clay

From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.RED CLAY

0 ft

8 ft

GREY SHALE

8

70

COAL


70

73

CLAY

73

90

DRILLING FIRM STOFFER DRILLINGDATE 5-24-80ADDRESS 621 TUSG AVE
NEWCOMERSTOWN, OHIOSIGNED Homer Stoffer

*If additional space is needed to complete well log, use next consecutive numbered form.