

1979
County Permit No.
130

WEL' LOG AND DRILLING REPORT

ORIGINAL

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

553661

COUNTY Miami TOWNSHIP Concord SECTION OF TOWNSHIP 18
OWNER Keith Ratick ADDRESS Troy
LOCATION OF PROPERTY 1545 Washington Rd. Troy Oh

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST

(Specify one by circling)

Casing diameter 5 5/8 Length of casing 40'-10" Test rate 20 gpm Duration of test 1 hrs
Type of screen _____ Length of screen _____ Drawdown 7 ft Date 6-26-79
Type of pump _____ Static level (depth to water) + 2' ft
Capacity of pump _____ Quality (clear, cloudy, taste, odor) clear
Depth of pump setting _____ Pump installed by _____
Date of completion _____

WELL LOG*

SKETCH SHOWING LOCATION

Formations: sandstone, shale,
limestone, gravel, clay

From

To

Clay - Boulders

0 ft

29 ft

Sand + Gravel

29

32

Clay

32

34

Sand + Gravel

34

38

Limestone

38

68

Locate in reference to numbered
state highways, street intersections, county roads, etc.

W

E

N

S

ST RT 718

ST RT 41

Washington Rd

RECEIVED

JUL 06 1979

HEALTH DEPARTMENT
TROY, OHIO

DRILLING FIRM Stoltz well Dr. Co.
ADDRESS Troy Oh.

DATE 7-6-79
SIGNED [Signature]