1979
County Permit No.
281

NO CARBON PAPER NECESSARY - SELF-TRANSCRIBING

WELL LOG AND DRILLING REPORT

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

ORIGINAL
18.

553688

COUNTY Miami TOWNSHIP Concord SECTION OF TOWNSHIP 12

OWNER M.E. Fifer ADDRESS Troy

LOCATION OF PROPERTY 3494 W. St. Rt. 41 Troy

CONSTRUCTION DETAILS

Casing diameter 5 5/8 Length of casing 85'4"

Type of screen _____ Length of screen _____

Type of pump _____

Capacity of pump _____

Depth of pump setting _____

Date of completion _____

BAILING OR PUMPING TEST
(specify one by circling)

Test rate 10 gpm Duration of test 2 hrs

Drawdown 23 ft Date 12-10-79

Static level (depth to water) 4 ft

Quality (clear, cloudy, taste, odor) Clear

Pump installed by _____

WELL LOG*

Formations: sandstone, shale, limestone, gravel, clay	From	To
Clay	0 ft	6 ft
Clay & Gravel	6	11
Clay	11	35
Sand & Gravel	35	41
Clay	41	64
Sand	64	84
Limestone	84	110

SKETCH SHOWING LOCATION

Locate in reference to numbered state highways, street intersections, county roads, etc.



DRILLING FIRM Stoltz Well Drlg.

ADDRESS Troy, O

DATE 12-12-79

SIGNED [signature]

*If additional space is needed to complete well log, use next consecutive numbered form.

18