

1980
County Permit No.
109

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

WELL LOG AND DRILLING REPORT

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

ORIGINAL

562760

3512

COUNTY Miami TOWNSHIP Concord SECTION OF TOWNSHIP 29
OWNER Susan Overholser ADDRESS Troy, Oh
LOCATION OF PROPERTY 1833 Edgewood Dr. Troy Oh

CONSTRUCTION DETAILS

Casing diameter 5 5/8 Length of casing 45'
Type of screen _____ Length of screen _____
Type of pump _____
Capacity of pump _____
Depth of pump setting _____
Date of completion _____

BAILING OR PUMPING TEST

(Specify one by circling)

Test rate 10 gpm Duration of test 2 hrs
Drawdown 17 ft Date 7-24-80
Static level (depth to water) 14 ft
Quality (clear, cloudy, taste, odor) Clear
Pump installed by _____

WELL LOG*

Formations: sandstone, shale,
limestone, gravel, clay

From


To

Clay	0 ft	14 ft
Clay & Gravel	14	16
Clay	16	35
Water Sand	35	44
Gravel	44	45

SKETCH SHOWING LOCATION

Locate in reference to numbered
state highways, street intersections, county roads, etc.

N



RECEIVED

JUL 30 1980

HEALTH DEPARTMENT
TROY, OHIO

DRILLING FIRM R.E. Scholtz Well Dr.
ADDRESS Troy, Oh.

DATE 7-28-80
SIGNED [Signature]

*If additional space is needed to complete well log, use next consecutive numbered form.

084