

County Permit No.

65637

WELL LOG AND DRILLING REPORT

ORIGINAL

State of Ohio

DEPARTMENT OF NATURAL RESOURCES

Division of Water

Fountain Square

Columbus, Ohio 43224

571811

NO CARBON PAPER

NECESSARY -

SELF-TRANSCRIBING

COUNTY Licking TOWNSHIP EDEN SECTION OF TOWNSHIP _____OWNER William Hofacker ADDRESS 11250 Houdeshell Rd NESt. Louisville, Ohio 43071LOCATION OF PROPERTY (Same As Above)

CONSTRUCTION DETAILS

28.5

Casing diameter 7" Length of casing 28.5'Type of screen - Length of screen -Type of pump Wabtrol SubmersibleCapacity of pump 10 gpmDepth of pump setting 82'Date of completion Aug 18 '89

BAILING OR PUMPING TEST

(Specify one by circling)

Test rate 12 gpm Duration of test 1/2 hrsDrawdown -0- ft Date Aug 20 '89

Static level (depth to water) _____ ft

Quality (clear, cloudy, taste, odor) CLEAR - NO ODORPump installed by W. Hofacker

WELL LOG*

SKETCH SHOWING LOCATION

Formations: sandstone, shale,
limestone, gravel, clay

From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

Top Soil, Shale

0 ft

5 ft

Brown Shale

5

15

Gray Shale (H₂O)

15

17

GRAY SHALE

17

20

Brown Shale (Set Pipe)

20

27.4

Brown Shale

27.4

30

Gray Shale

32

36

Brown Shale (Little H₂O)

36

56

Brown Shale

56

62

Gray Shale

62

64

Sandstone Brown

64

69

Brown Shale

69

80

Gray Shale

80

82

White Little Injun Sand (Lots H₂O)

82

85

Brown Shale

85

(90) T.D.

TO
WILKINS
CORNERS
& ST RT 79EDEN TOWNSHIP
MAY RUN TOWNSHIPCHANCEY
and
Gladys
Hofacker

Well site

STRADLEY
RDDRILLING FIRM Owner AboveDATE Sept 7 '89ADDRESS Same As AboveSIGNED William Hofacker

*If additional space is needed to complete well log, use next consecutive numbered form.