

WELL LOG AND DRILLING REPORT

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

594056

COUNTY FARFIELD TOWNSHIP WALNUT SECTION OF TOWNSHIP 32
OWNER William KAUFFMAN ADDRESS 1660 PLEASANTVILLE RD.
PLEASANTVILLE, OHIO 43148
LOCATION OF PROPERTY SAME

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST

(specify one by circling)

Casing diameter 6" Length of casing 96 FT.
Type of screen 5" PVC Length of screen 4 FT.
Type of pump SUBMERSIBLE
Capacity of pump 10 GPM
Depth of pump setting 87 FT.
Date of completion 8-31-83

Test rate 10 gpm Duration of test 3 hrs
Drawdown 41 ft Date 8-22-83
Static level (depth to water) 27 ft. ft
Quality (clear, cloudy, taste, odor) CLEAR
Pump installed by McBRIDE

WELL LOG*

SKETCH SHOWING LOCATION

Formations: sandstone, shale,
limestone, gravel, clay


From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

CLAY	0 ft	8 ft
CLAY & GRAVEL	8	70
SAND, Mud + WATER	70	72
CLAY & GRAVEL	72	85
CEMENTED GRAVEL	85	94
SAND, GRAVEL + WATER	94	99

WELL FINISHED 99 FT.



DRILLING FIRM McBRIDE Drilling Co
ADDRESS LANCASTER OHIO

DATE Aug. 31, 1983
SIGNED Tom McBride

*If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224