

WELL LOG AND DRILLING REPORT

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

594058

COUNTY FAIRFIELD TOWNSHIP Walnut SECTION OF TOWNSHIP 36
OWNER HAROLD KAUFFMAN ADDRESS 1410 PLEASANTVILLE RD.
PLEASANTVILLE, OHIO 43148
LOCATION OF PROPERTY SAME

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST

(specify one by circling)

Casing diameter 6" Length of casing 82'-4"
Type of screen 5" PVC Length of screen 4 FT.
Type of pump SUMMERSIBLE
Capacity of pump 18 G.P.M.
Depth of pump setting 70 ft.
Date of completion 10-5-83

Test rate 20 gpm Duration of test 6 hrs
Drawdown 3 ft Date 10/3/83
Static level (depth to water) 37 ft. ft
Quality (clear, cloudy, taste, odor) CLEAR
Pump installed by McBRIDE

WELL LOG*

SKETCH SHOWING LOCATION

Formations: sandstone, shale,
limestone, gravel, clay


From

To

CLAY & GRAVEL	0 ft	75 ft
SAND & WATER	75	76
CLAY & GRAVEL	76	80
SAND, GRAVEL & WATER	80	84


WELL FINISHED 85' FROM TOP
OF 6" PIPE.

Locate in reference to numbered
state highways, street intersections, county roads, etc.



W

E



DRILLING FIRM McBRIDE DRILLING Co.
ADDRESS LANCASTER, OHIO 43130

DATE Oct. 6, 1983
SIGNED Stan McBride

*If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224