

WELL LOG AND DRILLING REPORT

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

596233

COUNTY Stark TOWNSHIP Plain SECTION OF TOWNSHIP _____
OWNER Bud Michel ADDRESS 1400 Buena Vista, Canton
LOCATION OF PROPERTY 5141 Gross St., N.E., Canton, Ohio

CONSTRUCTION DETAILS

Casing diameter 7.5 Length of casing 227.207
Type of screen _____ Length of screen _____
Type of pump Myers
Capacity of pump 1/2 HP
Depth of pump setting 70 ft
Date of completion Dec. 30, 1981

BAILING OR PUMPING TEST

(specify one by circling)


Test rate 20 gpm Duration of test 5 hrs
Drawdown 0 ft Date Dec. 30, 1981
Static level (depth to water) 18 ft
Quality (clear, cloudy, taste, odor) Clear
Slight sulfur odor
Pump installed by A.B. Culp Drilling Co.

WELL LOG*

Formations: sandstone, shale, limestone, gravel, clay	From	To
<u>Sand & gravel</u>	<u>0 ft</u>	<u>14 ft</u>
<u>Shale</u>	<u>14</u>	<u>46</u>
<u>Limestone</u>	<u>46</u>	<u>52</u>
<u>Coal</u>	<u>52</u>	<u>54</u>
<u>Blue & gray shale</u>	<u>54</u>	<u>133</u>
<u>Limestone</u>	<u>133</u>	<u>135</u>
<u>Blue shale</u>	<u>135</u>	<u>176</u>
<u>Gray shale</u>	<u>176</u>	<u>184</u>
<u>Blue shale</u>	<u>184</u>	<u>202</u>
<u>Hard gray shale</u>		
<u>Gray sandstone</u>	<u>202</u>	<u>274</u>
<u>White sandstone</u>	<u>274</u>	<u>300</u>

SKETCH SHOWING LOCATION

Locate in reference to numbered
state highways, street intersections, county roads, etc.



DRILLING FIRM A.B. Culp Drilling Co.

DATE December 31, 1981

ADDRESS 1601 Hastic Blvd, N.E., Canton, Ohio 44601

SIGNED Arri Michel
Bookkeeper

*If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224