

WELL LOG AND DRILLING REPORT

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

596235

COUNTY Stark TOWNSHIP Free SECTION OF TOWNSHIP _____
OWNER David Petty ADDRESS 12272 Hoover Rd, Uniontown
LOCATION OF PROPERTY 12272 Hoover Rd, Uniontown

CONSTRUCTION DETAILS

Casing diameter 5 Length of casing 55 ft.
Type of screen 4" tele Length of screen 5 ft.
Type of pump Myers
Capacity of pump 1/2 HP
Depth of pump setting 20 feet
Date of completion 5-23-82

BAILING OR PUMPING TEST

(specify one by circling)

Test rate 15 gpm Duration of test 48 hrs
Drawdown 3 1/4 ft Date 4-22-82
Static level (depth to water) 2 1/2 ft
Quality (clear, cloudy, taste, odor) Slightly Cloudy
no odor
Pump installed by TO BE C.B. Culp Drilling Co.

WELL LOG*

Formations: sandstone, shale,
limestone, gravel, clay

From

To


0 ft

55 ft

Sand & gravel

SKETCH SHOWING LOCATION

Locate in reference to numbered
state highways, street intersections, county roads, etc.



DRILLING FIRM C.B. Culp Drilling Co.

DATE April 23, 1982

ADDRESS 6901 Atlantic Blvd NE

SIGNED Mark Shuster

*If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224