

WELL LOG AND DRILLING REPORT

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

596503

COUNTY Warren TOWNSHIP Franklin SECTION OF TOWNSHIP 32
OWNER Gene Clendenen ADDRESS 6900 Scholl Rd. Franklin D
LOCATION OF PROPERTY 3 1/4 South State Rte 123 Castlebrooke Subdivision

CONSTRUCTION DETAILS

Casing diameter 6" Length of casing 42'
Type of screen 1/4" Length of screen 15'
Type of pump _____
Capacity of pump _____
Depth of pump setting _____
Date of completion _____

BAILING OR PUMPING TEST

(specify one by circling)

Test rate 10 gpm Duration of test 2 hrs
Drawdown 5 ft Date 4/28/81
Static level (depth to water) 20 ft
Quality (clear, cloudy, taste, odor) Clear
Pump installed by _____

WELL LOG*

Formations: sandstone, shale,
limestone, gravel, clay

From

To

yellow clay
sand & gravel

0 ft

15 ft

15


42

Water at 30'

W

SKETCH SHOWING LOCATION

Locate in reference to numbered
state highways, street intersections, county roads, etc.



DRILLING FIRM

Whitaker S. Day

DATE

4/30/81

ADDRESS

7023 Hurwitzer Dr. Franklin D

SIGNED

W. S. Day

*If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224

324