

WELL LOG AND DRILLING REPORT

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

165
599277

COUNTY CARROLL TOWNSHIP HARRISON SECTION OF TOWNSHIP 22
OWNER THOMAS MICKEL ADDRESS 2173 ARROW RD. CARROLLTON OH 44615
LOCATION OF PROPERTY 2173 ARROW RD.

CONSTRUCTION DETAILS

Casing diameter 6" Length of casing 63'
Type of screen NONE Length of screen _____
Type of pump DEEP WELL PUMP
Capacity of pump 7 GPM
Depth of pump setting 82'
Date of completion 6/5/84

BAILING OR PUMPING TEST

(Specify one by circling)


Test rate 20 gpm Duration of test 2 hrs
Drawdown 20' ft Date 6/1/84
Static level (depth to water) 10' ft
Quality (clear, cloudy, taste, odor) CLEAR
Pump installed by JERRY NICHOLS

WELL LOG*

Formations: sandstone, shale, limestone, gravel, clay	From	To
<u>CLAY</u>	<u>0 ft</u>	<u>6 ft</u>
<u>SANDSTONE</u>	<u>6'</u>	<u>25'</u>
<u>SHALE</u>	<u>25'</u>	<u>43'</u>
<u>CLAY & SHALE</u>	<u>43'</u>	<u>60'</u>
<u>SANDSTONE</u>	<u>60'</u>	<u>68'</u>
<u>SHALE</u>	<u>68'</u>	<u>80'</u>
<u>SANDSTONE</u>	<u>80'</u>	<u>92'</u>
<u>WATER AT 82'</u>		

SKETCH SHOWING LOCATION

Locate in reference to numbered
state highways, street intersections, county roads, etc.



DRILLING FIRM JERRY NICHOLS WELL DRILLING
1001 Kensington Rd. N.E.
ADDRESS _____

DATE 6/5/84
SIGNED Jerry Nichols

*If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224

193