

WELL LOG AND DRILLING REPORT

185
✓

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

599836

COUNTY Madison TOWNSHIP Union SECTION OF TOWNSHIP Union SE
OWNER Charles Post ADDRESS 4802 St. Rt. 665 SE
LOCATION OF PROPERTY 4802 St. Rt. 665 S.E. London Ohio 43140

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST

(specify one by circling)

Casing diameter 6" O.D. Length of casing 95
Type of screen _____ Length of screen _____
Type of pump _____
Capacity of pump _____
Depth of pump setting 75'
Date of completion _____

Test rate 12 gpm Duration of test 1 hrs
Drawdown 8 ft Date 12-25-83
Static level (depth to water) 30 ft
Quality (clear, cloudy, taste, odor) Clear
Pump installed by Quality Homes

WELL LOG*

SKETCH SHOWING LOCATION


Formations: sandstone, shale,
limestone, gravel, clay

From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

Black Clay	0 ft	22 ft
Boulders	22	28
tan clay & gravel mix	28	46
Blue clay & gravel mix	46	93
Sand & gravel	93	
Completed	95	



DRILLING FIRM Plains Drilling Company
ADDRESS Rt. 4 London Ohio

DATE 8-11-83
SIGNED Fred C. Blake

*If additional space is needed to complete well log, use next consecutive numbered form.