

WELL LOG AND DRILLING REPORT

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

600612

COUNTY Morrow TOWNSHIP Congress SECTION OF TOWNSHIP _____
OWNER Eileen Ghent ADDRESS 6530 Co Rd 76 Mt Gilead, O
LOCATION OF PROPERTY 3 mi North of St Rt 42 on Co Rd 76

CONSTRUCTION DETAILS	BAILING OR PUMPING TEST (specify one by circling)
Casing diameter <u>5</u> Length of casing <u>103</u>	Test rate <u>10</u> gpm Duration of test <u>2</u> hrs
Type of screen <u>in</u> Length of screen <u>in</u>	Drawdown <u>15</u> ft Date _____
Type of pump <u>Deep well</u>	Static level (depth to water) <u>60</u> ft
Capacity of pump <u>10 GPM</u>	Quality (<u>clear</u> , cloudy, taste, odor) _____
Depth of pump setting <u>96'</u>	Pump installed by <u>Rogers + Son</u>
Date of completion <u>9-18-01</u>	

WELL LOG*			SKETCH SHOWING LOCATION
Formations: sandstone, shale, limestone, gravel, clay	From	To	Locate in reference to numbered state highways, street intersections, county roads, etc.
<u>Top Soil Silt</u>	0 ft	12 ft	N E
<u>Blue Clay</u>	12	24	
<u>Sand</u>	24	34	
<u>Gravel + Clay</u>	34	51	
<u>Sand + Gravel</u>	51	63	
<u>Sand</u>	63	96	
<u>Sand Stone</u>	96	103	
<u>Water 96 ft</u>			

DRILLING FIRM Rogers + Son DATE 10-4-01
ADDRESS 5061 Co Rd 29 Galion 44833 SIGNED W. D. Rogers

*If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224