

WELL LOG AND DRILLING REPORT

NO CARBON PAPER
NECESSARY-
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

600867

COUNTY LORAIN TOWNSHIP AVON SECTION OF TOWNSHIP _____
OWNER MARK DUDZIAK ADDRESS AVON O
LOCATION OF PROPERTY 36412 MILLS Rd AVON O.

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST (specify one by circling)

Casing diameter 5 Length of casing 34
Type of screen — Length of screen _____
Type of pump SUBMERSIBLE
Capacity of pump 56PM FLOW VALVE
Depth of pump setting 70
Date of completion 11-5-82

Test rate 5 gpm Duration of test 1 hrs
Drawdown 20 ft Date 11-1-82
Static level (depth to water) 2 ft
Quality (clear, cloudy, taste, odor) CLEARING
NO ODOR TRACE OF SALT
Pump installed by B SCHUSTER

WELL LOG*

SKETCH SHOWING LOCATION

Formations: sandstone, shale,
limestone, gravel, clay

From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

YELLOW CLAY	0 ft	10 ft
BLUE CLAY	10	27
SAND	27	28
SANDSTONE	28	73
GREY SHALE	73	74
WATER AT 56PM 70'		

W

STONE RIDGE Rd

MILLS Rd

RT 83

N

E

S

DRILLING FIRM BERN SCHUSTER
ADDRESS ELYRIA O

DATE 11-5-82
SIGNED B Schuster

*If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224