

# WEI LOG AND DRILLING REPORT

172

NO CARBON PAPER  
NECESSARY -  
SELF-TRANSCRIBING

State of Ohio  
DEPARTMENT OF NATURAL RESOURCES  
Division of Water  
Fountain Square  
Columbus, Ohio 43224

601156

COUNTY Wayne TOWNSHIP Baughman SECTION OF TOWNSHIP 5  
OWNER Allen Wiles ADDRESS 134 CADDEN HILL OARVILLE  
LOCATION OF PROPERTY ON S.R. 94 1/2 mi SO. OF Marshallville

## CONSTRUCTION DETAILS

## BAILING OR PUMPING TEST (specify one by circling)

Casing diameter 5" Length of casing 96'  
Type of screen — Length of screen —  
Type of pump Sub  
Capacity of pump 10  
Depth of pump setting —  
Date of completion —  
Test rate 12 gpm Duration of test 2 hrs  
Drawdown 40 ft Date 6-3-81  
Static level (depth to water) 64' ft  
Quality (clear, cloudy, taste, odor) clear  
Pump installed by H & H pump Rittman

## WELL LOG\*

## SKETCH SHOWING LOCATION

Formations: sandstone, shale,  
limestone, gravel, clay

From

To

Locate in reference to numbered  
state highways, street intersections, county roads, etc.

|              |      |       |
|--------------|------|-------|
| SURFACE Clay | 0 ft | 18 ft |
| Soft Shale   | 18   | 30    |
| Sand Rock    | 30   | 58    |
| Shale        | 58   | 132   |
| Sand Rock    | 132  | 166   |

W

N

E

S

Marshallville

S.R. 94

x well

Fox Lake Rd.

R.R. TO AKRON

DRILLING FIRM

ADDRESS

DATE

SIGNED

\*If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224 / 6