

WELL LOG AND DRILLING REPORT

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

601562

COUNTY Stark TOWNSHIP Bethlehem SECTION OF TOWNSHIP _____

OWNER Tom Farris ADDRESS _____

LOCATION OF PROPERTY 6958 Shepherd Church

CONSTRUCTION DETAILS

Casing diameter 4 Length of casing 68
Type of screen _____ Length of screen _____
Type of pump _____
Capacity of pump _____
Depth of pump setting _____
Date of completion 3-26-81

BAILING OR PUMPING TEST

(specify one by circling)


Test rate 15 gpm Duration of test 2 hrs
Drawdown 0 ft Date 3-26-81
Static level (depth to water) 25 ft
Quality (clear, cloudy, taste, odor) clear
Pump installed by _____

WELL LOG*

Formations: sandstone, shale, limestone, gravel, clay	From	To
<u>clay & gravel</u>	0 ft	52 ft
<u>coal</u>	52	54
<u>Soft Shale</u>	54	67
<u>Shale</u>	67	98

SKETCH SHOWING LOCATION

Locate in reference to numbered
state highways, street intersections, county roads, etc.



DRILLING FIRM Sponser Drilling Inc.

DATE 4-23-81