486

WELL LOG AND DRILLING REPORT

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

NO CARBON PAPER NECESSARY– SELF-TRANSCRIBING

601563

COUNTY Wayne TOWNSHIP Green SECTION OF TOWNSHIP 6

OWNER Eddy L. Morth ADDRESS 4922 Fox Lake Rd

LOCATION OF PROPERTY Same

CONSTRUCTION DETAILS

Casing diameter 5" Length of casing 44

Type of screen _____ Length of screen _____

Type of pump Submersible

Capacity of pump 10 GPM

Depth of pump setting 60'

Date of completion 4-28-81

BAILING OR PUMPING TEST
(specify one by circling)

Test rate 20 gpm Duration of test 2 hrs

Drawdown 0 ft Date 4-28-81

Static level (depth to water) 40 ft

Quality (clear, cloudy, taste, odor) clear

Pump installed by Spencer Drilling

WELL LOG*

Formations: sandstone, shale, limestone, gravel, clay	From	To
clay	0 ft	38 ft
Soft Sandrock	38	42
Sandrock	42	92
Shale	92	110

SKETCH SHOWING LOCATION

Locate in reference to numbered state highways, street intersections, county roads, etc.



DRILLING FIRM Spencer Drilling Inc. DATE 5-13-81

ADDRESS 11490 Millbury Rd, Millbury SIGNED R. Spencer

*If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224

15