

WELL LOG AND DRILLING REPORT

NO CARBON PAPER
NECESSARY—
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

603340

COUNTY Medina TOWNSHIP Hinckley SECTION OF TOWNSHIP SE
OWNER C. R. Turney ADDRESS 2640 State Rd Hinckley
LOCATION OF PROPERTY 645 Ledyer Rd 1/4 mi. W. of State Rd

CONSTRUCTION DETAILS

Casing diameter 5" Length of casing 32'
Type of screen — Length of screen —
Type of pump Sub
Capacity of pump 600 GPH
Depth of pump setting 80
Date of completion 10-4-82

BAILING OR PUMPING TEST

(specify one by circling)

Test rate 12 gpm Duration of test 1 hrs
Drawdown 50 ft Date 10-4-82
Static level (depth to water) 18' ft
Quality (clear, cloudy, taste, odor) Clear
Pump installed by Waterbury

WELL LOG*

Formations: sandstone, shale, limestone, gravel, clay

From

To

Clay + Gravel
Shale

0 ft

34 ft

34

90

Water 76'

SKETCH SHOWING LOCATION

Locate in reference to numbered state highways, street intersections, county roads, etc.

N

W

Lodge Rd

E

S

DRILLING FIRM Wershmy W.D.
ADDRESS Hinckley Ohio

DATE 10-5-82
SIGNED Ray C. Wender

• If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224