

WELL LOG AND DRILLING REPORT

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING
permit # 9494

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
H.B. Division of Water
Fountain Square
Columbus, Ohio 43224

607046

COUNTY Stark TOWNSHIP Jackson SECTION OF TOWNSHIP 7
OWNER David Gibbs (John Zelek Homes) ADDRESS 9410 Hocking St, Massillon, OH 44646
LOCATION OF PROPERTY 7605 Onyx Circle, Massillon, OH 44646

CONSTRUCTION DETAILS

Casing diameter 5" Length of casing 85'
Type of screen _____ Length of screen _____
Type of pump _____
Capacity of pump _____
Depth of pump setting _____
Date of completion _____

~~DRILLING~~ OR PUMPING TEST (specify one by circling)


Test rate 16 gpm Duration of test 2 hrs
Drawdown 1' ft Date 9/22/82
Static level (depth to water) 51 ft
Quality (clear, cloudy, taste, odor) clear
Pump installed by _____

WELL LOG*

Formations: sandstone, shale, limestone, gravel, clay	From	To
drift	0 ft	72 ft
shale	72	105
sandstone	105	132
shale	132	140

SKETCH SHOWING LOCATION

Locate in reference to numbered state highways, street intersections, county roads, etc.



ADAMS & SONS

DRILLING FIRM Well Drilling, Inc.
ADDRESS 4310 - 38th St., N.W.
492-0150 Centes, Ohio 44718

DATE 9/23/82
SIGNED John Adams

*If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224