

NO CARBON PAPER
NECESSARY—
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

607464

COUNTY Perry TOWNSHIP Reading SECTION OF TOWNSHIP Reading
OWNER Tara Meadows ADDRESS 226 S. Eastwood Ave.
LOCATION OF PROPERTY At #22 4 Miles N. of Somerset 3rd lot from attention Rd.

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST

(specify one by circling)

Casing diameter 5 1/2" Length of casing 25'
 Type of screen none Length of screen _____
 Type of pump Goulds
 Capacity of pump 10 gal. min.
 Depth of pump setting 60'
 Date of completion _____

Test rate 12 gpm Duration of test one hrs
 Drawdown 10' ft Date 5-13-25
 Static level (depth to water) 30' ft
 Quality (clear, cloudy, taste, odor) _____
 Pump installed by _____

WELL LOG*

SKETCH SHOWING LOCATION

Formations: sandstone, shale,
limestone, gravel, clay

From

To

0 ft

12 ft

17

65

Clay
gray shale

Locate in reference to numbered
state highways, street intersections, county roads, etc.

N

W

Somerset
 4 Miles ON State Rt 22
 110'
 Third Lot
 West of Otterbolen Rd
 Otterbolen Rd.
 white column

LOCATED
230

S

DRILLING FIRM Miller Drilling

DATE 5-13-84

ADDRESS 6435 Tent Church Rd

SIGNED John Miller

• If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224