

WEI' LOG AND DRILLING REPORT

799

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

607874

COUNTY FRANKLIN TOWNSHIP JACKSON SECTION OF TOWNSHIP _____
OWNER Bob Pyles ADDRESS SAME
LOCATION OF PROPERTY 4134 BRIAR BROOK, GROVE CITY OH 43123

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST

(specify one by circling)

Casing diameter 5 1/2 Length of casing 167' Test rate 15 gpm Duration of test 2 hrs
Type of screen — Length of screen — Drawdown 15 ft Date 5-21-88
Type of pump — Static level (depth to water) 69' ft
Capacity of pump — Quality (clear, cloudy, taste, odor) CLEAR
Depth of pump setting 110'
Date of completion 5/20/88 Pump installed by Vincent Pump

WELL LOG*

SKETCH SHOWING LOCATION

Formations: sandstone, shale,
limestone, gravel, clay

From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

Yellow Clay

0 ft

20 ft

Permit 8800112

N

Blue Clay

20

50

HARD PAN

50

120

SAND

120

166

Limestone

166

167

W

Harver Rd

White Rd

71

E

615'5
225
166
599

S

Hillswood

BRIAR BROOK

4134

DRILLING FIRM Underhill Well DRILLING DATE 5-23-88
ADDRESS 241 West MAIN West Jefferson OH 43082 SIGNED Larry Underhill

*If additional space is needed to complete well log, use next consecutive numbered form.

510 D

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224