

WELL LOG AND DRILLING REPORT

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

609824

COUNTY Lucas TOWNSHIP Waterville SECTION OF TOWNSHIP _____
OWNER Village of Whitehouse ADDRESS _____
LOCATION OF PROPERTY Village of Whitehouse

CONSTRUCTION DETAILS

Casing diameter 10" Length of casing 41'10"
Type of screen _____ Length of screen _____
Type of pump _____
Capacity of pump _____
Depth of pump setting _____
Date of completion _____

BAILING OR PUMPING TEST (specify one by circling)

Test rate 490 gpm Duration of test 24 hrs
Drawdown 76.23 ft Date _____
Static level (depth to water) 32.67 ft
Quality (clear, cloudy, taste, odor) _____
Pump installed by _____

WELL LOG*

Formations: sandstone, shale, limestone, gravel, clay	From	To
	0 ft	ft
<u>Clay</u>	<u>0</u>	<u>40</u>
<u>Limestone</u>	<u>40</u>	<u>170</u>

SKETCH SHOWING LOCATION

Locate in reference to numbered
state highways, street intersections, county roads, etc.

N

Well #3

W E

S

Well initially acidized - could not pump - poor weather. Pumped less than initial yield - Therefore acidized second time - Pumping test conducted by Engen & Associates.

DRILLING FIRM Dumbar Drilling
ADDRESS Sevastian

DATE 4/5/84
SIGNED Dale Dumbar (J.D.)

*If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224