

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

611249

Permitt 48884

COUNTY Wood TOWNSHIP Lake SECTION OF TOWNSHIP 10
OWNER Walter Knudson ADDRESS 3941 Ayres Rd.,
Millbury, Ohio 43447
LOCATION OF PROPERTY 18740 Lemoyne Rd.

CONSTRUCTION DETAILS		BAILING OR PUMPING TEST (specify one by circling)	
Casing diameter <u>5 5/8</u>	Length of casing <u>70'</u>	Test rate <u>10</u> gpm	Duration of test <u>2</u> hrs
Type of screen _____	Length of screen _____	Drawdown <u>10</u> ft	Date <u>9-28-87</u>
Type of pump <u>Submersible</u>		Static level (depth to water) <u>58</u> ft	
Capacity of pump <u>10 GPM</u>		Quality (<u>clear</u> , cloudy, taste, odor) _____	
Depth of pump setting <u>100</u>			
Date of completion <u>10-7-87</u>		Pump installed by <u>Wendell Bibbs</u>	

[illegible]

DRILLING FIRM BITT'S Well Drilling
ADDRESS Walbridge, Ohio

DATE 9-28-87
SIGNED Wendell Bihm

*If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224