WELL LOG AND DRILLING REPORT

NO CARBON PAPER NECESSARY – SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

300
611980
2236 all

COUNTY Carroll TOWNSHIP Brown SECTION OF TOWNSHIP

OWNER Ruth Householder, 2236 Alliance Rd. (Rt. #183), Malvern, Ohio 44644 ADDRESS

LOCATION OF PROPERTY SAME

CONSTRUCTION DETAILS

Casing diameter 5" Length of casing 32' in grd

Type of screen Length of screen

Type of pump

Capacity of pump

Depth of pump setting 60'

Date of completion

BAILING OR PUMPING TEST
(specify one by circling)

Test rate see below gpm Duration of test 1 hrs

Drawdown ft Date Oct. 19, 1984

Static level (depth to water) 42 ft

Quality (clear, cloudy, taste, odor) clear, odorless, 11 grains hard; 7.9 pH; no measurable iron

Pump installed by

WELL LOG*

Formations: sandstone, shale, limestone, gravel, clay	From	To
Overburden	0 ft	5 ft
Clay	5'	16'
Clay & broken shale	16'	26'
Shale	26'	40'
Coal	40'	43'
Shale	43'	85'

SKETCH SHOWING LOCATION

Locate in reference to numbered state highways, street intersections, county roads, etc.

N

AIR TEST

85' - 30 gpm
75' - 30 gpm
60' - 20 gpm

W E

S

DRILLING FIRM BROGAN WELL DRILLING COMPANY
ADDRESS 7103 Columbus Rd. N.E. Louisville, Ohio 44641

DATE October 19, 1984
SIGNED Paul D. Brogan

*If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224

154