

WELL LOG AND DRILLING REPORT

State of Ohio

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

612206

COUNTY FULTON TOWNSHIP YORK SECTION OF TOWNSHIP 30
OWNER DICK HARNER ADDRESS CO RD 'E', WAYSEON, OH.
LOCATION OF PROPERTY ON RD 'E' 500' EAST OF RD '13'

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST

(specify one by circling)

Casing diameter 5 Length of casing 156

Test rate 8 gpm Duration of test 1 hrs

Type of screen _____ Length of screen _____

Drawdown 10 ft Date 6-15-85

Type of pump SUBMERISIB P

Static level (depth to water) 7.2 ft

Capacity of pump 300 G. P. M.

Quality (clear, cloudy, taste, odor) CLEAR

Depth of pump setting 10.5'

Date of completion 6-19-85

Pump installed by DALE B. G.

WELL LOG*

SKETCH SHOWING LOCATION

Formations: sandstone, shale,
limestone, gravel, clay

From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

	0 ft	8 ft
YELLOW SAND		
YELLOW CLAY	8	14
GRAY CLAY	14	130
GRAY CLAY - STONES	130	145
HARD PAN	145	154
BLACK GRAVEL	154	156
BLACK O. SHALE	156	166

N

W

E

S

DRILLING FIRM W. J. Smith

DATE 1-21-55

ADDRESS Kalam, B.

SIGNED John F. Hall

*If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224

32