

WELL LOG AND DRILLING REPORT

State of Ohio

NO CARBON PAPER
NECESSARY-
SELF-TRANSCRIBING

DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

612208

COUNTY FULTON TOWNSHIP ~~CLINTON~~ SECTION OF TOWNSHIP 3
OWNER HARRY BORTON ADDRESS 1-12552-4520, LYONS, OH 43533
LOCATION OF PROPERTY ON Rd '10' 1/2 mi S of Rd 'C'

CONSTRUCTION DETAILS

Casing diameter 4" Length of casing 80'
Type of screen - Length of screen -
Type of pump SUBMERSIBLE
Capacity of pump 7 G.P.M.
Depth of pump setting 63'
Date of completion 8-29-85

BAILING OR PUMPING TEST

(specify one by circling)

Test rate 10 gpm Duration of test 1 hrs
Drawdown 15 ft Date 8-27-85
Static level (depth to water) 25 ft
Quality (clear, cloudy, taste, odor) CLEAR
Pump installed by DRILLER

WELL LOG*

[illegible]

SKETCH SHOWING LOCATION

Locate in reference to numbered
state highways, street intersections, county roads, etc.

A hand-drawn map showing a grid. At the top is the letter 'N' and at the bottom is 'S'. On the left, 'RD 10' is written. In the center, 'sec 3' is written. On the right, 'B' and 'C' are written. A vertical line is labeled '1/2 mi' with arrows pointing up and down, and an 'X' is marked on the line.

DRILLING FIRM BYRON SHAFFER
ADDRESS RD 2, WAUSEON, OH 43567

DATE 8-30-85
SIGNED Brian R. [Signature]

*If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224