

WELL LOG AND DRILLING REPORT

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

614266

COUNTY Union TOWNSHIP Taylor SECTION OF TOWNSHIP N/W
OWNER Lloyd Handren ADDRESS 22517 McAdow Rd. Marysville Ohio 43040
LOCATION OF PROPERTY 6 mile North of Marysville, Ohio on McAdow Rd, Marysville, Ohio

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST
(specify one by circling)

(specify one by circling)

Casing diameter 4 1/4 Length of casing 56'
Type of screen — Length of screen —
Type of pump submersible
Capacity of pump 1.5 DPM
Depth of pump setting 48'
Date of completion 9/29/53

Test rate 20 gpm Duration of test 24 hrs
Drawdown none ft Date 9/25/83
Static level (depth to water) 30 ft
Quality (clear, cloudy, taste, odor) Clear
Pump installed by Owner

WELL LOG*

SKETCH SHOWING LOCATION

Formations: sandstone, shale,
limestone, gravel, clay

From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

Clay	0 ft	12 ft
fine sand	12	36
hard pan	36	53
gravel	53	56

N

0411

Co. Rd 205 $\frac{1}{2}$ Mile
Meadow Rd
T200

CO. RD 205

W

E

9-31

○-Marysville, Chi

DRILLING FIRM Motts Water Well Drilling
ADDRESS 745 N. Maple St, Marysville
Ohio 43040

DATE 10/8/83
SIGNED Richard A. Most, John C. Most
secutive numbered form.

*If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224