

WELL LOG AND DRILLING REPORT

#162

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

614482

Permit # 48

COUNTY Franklin TOWNSHIP Jackson SECTION OF TOWNSHIP L-2
OWNER Mr. Mark Miller ADDRESS 5962 Aralia Court Gallaway Ohio 43110
LOCATION OF PROPERTY 1690 Zuber Road Grove City, Ohio 43123

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST

(specify one by circling)

Casing diameter 5 1/2 od Length of casing 94 ft.
Type of screen None Length of screen XX
Type of pump Deep Well
Capacity of pump 10 gpm
Depth of pump setting 75 ft.
Date of completion 6/27/84

Test rate 10 gpm Duration of test 24 hrs.
Drawdown None ft Date 6/25/84
Static level (depth to water) 30 ft.
Quality (clear, cloudy, taste, odor) Clear, Unknown
Pump installed by Peacock Drilling Co Registration #0082

WELL LOG*

SKETCH SHOWING LOCATION

Formations: sandstone, shale,
limestone, gravel, clay

From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

Clay

0 ft

50 ft

Clay & Gravel

50

80

Sand (fine)


80

90

Sand & Gravel

90

94



DRILLING FIRM Peacock Drilling Co.
ADDRESS 6955 Harrisburg Pike
Orient Ohio 43146

DATE June 27, 1984

SIGNED

Ralph J. Peacock
822

*If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224