WELL LOG AND DRILLING REPORT

#6

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

NO CARBON PAPER NECESSARY– SELF-TRANSCRIBING

614486

COUNTY Franklin TOWNSHIP Jackson SECTION OF TOWNSHIP L-2

OWNER Larry Petitti ADDRESS 621 Hibbs Rd. Grove City -43123

LOCATION OF PROPERTY North of 665 axp 1 1/2 miles on Hibbs Rd.

CONSTRUCTION DETAILS

Casing diameter w5 1/2" Length of casing 55ft.

Type of screen None Length of screen XX

Type of pump Deep well

Capacity of pump 18 gpm

Depth of pump setting 40 ft.

Date of completion Nov. 10, 1984

BAILING OR ~~PUMPING TEST~~
(specify one by circling)

Test rate 20 gpm Duration of test 24 hrs

Drawdown None ft Date Nov. 10, 1984

Static level (depth to water) 25 ft. ft

Quality (clear, cloudy, taste, odor) Clear, None

Pump installed by Owner

WELL LOG*

Formations: sandstone, shale, limestone, gravel, clay	From	To
Clay	0 ft	50 ft
Sand	50	52
Sand & Gravel	52	55

SKETCH SHOWING LOCATION

Locate in reference to numbered state highways, street intersections, county roads, etc.



DRILLING FIRM Peacock Drilling Co. DATE Nov. 10 1984

ADDRESS 6055 Harrisburg Pike Orient 43146 SIGNED

*If additional space is needed to complete well log, use next consecutive numbered form.

766

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224