

WELL LOG AND DRILLING REPORT

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

617723

COUNTY Pickaway TOWNSHIP Wayne SECTION OF TOWNSHIP _____
OWNER Mark Flynn ADDRESS St. Rte 104
LOCATION OF PROPERTY 1/2 mile south of Rt 2 on 104 west side of Rd

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST (specify one by circling)

Casing diameter <u>5 1/2</u> Length of casing <u>75</u>	Test rate <u>20</u> gpm Duration of test <u>1</u> hrs
Type of screen <u>Perforated</u> Length of screen <u>2 1/2</u>	Drawdown _____ ft Date <u>11-13-87</u>
Type of pump _____	Static level (depth to water) <u>75</u> ft
Capacity of pump <u>Owner installed</u>	Quality (clear, cloudy, taste, odor) <u>cloudy</u>
Depth of pump setting _____	
Date of completion _____	Pump installed by <u>Owner</u>

WELL LOG*

SKETCH SHOWING LOCATION


Formations: sandstone, shale,
limestone, gravel, clay

From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

Soil / clay	0 ft	12 ft
Brown clay & gravel	12	53
Sand & gravel	53	75



milling well Driller 11-22-87