

WELL LOG AND DRILLING REPORT

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

618113

179

COUNTY FRANKLIN TOWNSHIP MADISON SECTION OF TOWNSHIP _____

OWNER TOM DEIBLE ADDRESS 3160 TOY RD.

LOCATION OF PROPERTY 200 FT. E. OF ALUM CR. DR. ON TOY RD.

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST

(specify one by circling)

Casing diameter 4 1/4 Length of casing 99 Test rate 16 gpm Duration of test 2 hrs

Type of screen _____ Length of screen _____ Drawdown 2 ft Date _____

Type of pump _____ Static level (depth to water) 40 ft. ft.

Capacity of pump _____ Quality (clear, cloudy, taste, odor) _____

Depth of pump setting _____

Date of completion _____ Pump installed by _____

WELL LOG*

SKETCH SHOWING LOCATION

Formations: sandstone, shale,
limestone, gravel, clay

From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

CLAV

0 ft

35 ft

SAND, GRAVEL, CLAY

35

45

CLAY

465

69

SAND + GRAVEL

69

99

PERF CASING

DRILLING FIRM

ADDRESS 1913 TADD AVE.

DATE

DATE FEB. 20, 1986

SIGNED

SIGNED Sam Lewis

*If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224 104.5