

15 ✓

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

COUNTY PALMDING TOWNSHIP JACKSON SECTION OF TOWNSHIP SEC-33
OWNER MRS LEE ADDRESS RT-1 - PALMDING
LOCATION OF PROPERTY IN ABILLAGES OF HEDGES HOME WEST OF MELROSE
ON RT-1013-

CONSTRUCTION DETAILS			BAILING OR PUMPING TEST (specify one by circling)	
Casing diameter <u>4 1/4</u>	Length of casing <u>35</u>	Test rate <u>4</u> gpm Duration of test <u>2</u> hrs		
Type of screen <u>V 1/4</u>	Length of screen <u>L</u>	Drawdown <u>5</u> ft Date <u>9-8-82</u>		
Type of pump <u>JET -</u>		Static level (depth to water) <u>15 F.T.</u> ft		
Capacity of pump <u>6 G.P.M.</u>		Quality (clear, cloudy, taste, odor) <u>CLEAR - (NO ODOR)</u>		
Depth of pump setting <u>40 F.T.</u>		<u>(GOOD TASTE)</u>		
Date of completion <u>9-8-82</u>		Pump installed by <u>OWNER -</u>		
WELL LOG*			SKETCH SHOWING LOCATION	
Formations: sandstone, shale, limestone, gravel, clay	From	To	Locate in reference to numbered state highways, street intersections, county roads, etc.	
<u>YELLOW CLAY</u>	0 ft	12 ft	N	
<u>SANDY CLAY</u>	12	24		
<u>HARD PAN</u>	24	34		
<u>LIME STONE</u>	34	45		
<u>WATER AT</u>	<u>40 ft.</u>		W E	
			S	

DRILLING FIRM Spitz & Sons Well Drilling DATE 9.8.82
ADDRESS Continental Ohio SIGNED Carl Spitz

*If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224 40