

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

COUNTY DEFIANCE TOWNSHIP RICHLAND SECTION OF TOWNSHIP SEC. 35
OWNER ALAN - FAITZ ADDRESS RT-6. DEFIANCE. OHIO
LOCATION OF PROPERTY 1 1/2 miles from STANLEY O. OH - 3/8 -

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST

(specify one by circling)

Casing diameter 4 1/2 Length of casing 68
 Type of screen V Length of screen L
 Type of pump SUB -
 Capacity of pump 12 - G.P.M.
 Depth of pump setting 65 F.T.
 Date of completion 5-24-83

Test rate 20 gpm Duration of test 2 hrs
 Drawdown 10 ft Date 5-24-83
 Static level (depth to water) 19 F.T. ft
 Quality (clear, cloudy, taste, odor) CLEAR -
NO - ODOOR -
 Pump installed by PLUMBER -

WELL LOG*

SKETCH SHOWING LOCATION

Formations: sandstone, shale,
limestone, gravel, clay

From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

YELLOW CLAY	0 ft	13 ft
GRAY CLAY	13	58
HARD PAN	58	65
GRAVEL	65	68
LIME STONE	68	69
WATER AT 69 FT.		

HIGHWAY
CENTERED

N

STANDLEY RD.

WELL

MARK'S
FLD

PLEASE
BEN
X

W

E

RT-634

RT-15

CONTINENTAL
X D.

S

DRILLING FIRM**ADDRESS**

DATE _____

SIGNED

*If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224