WE LOG AND DRILLING RE ORT

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

NO CARBON PAPER NECESSARY– SELF-TRANSCRIBING

624080

COUNTY Licking TOWNSHIP Hartford SECTION OF TOWNSHIP

OWNER Berkshire Homes Sub 755 ADDRESS Box 707 Delaware, Oh.

LOCATION OF PROPERTY Roberts Rd.

CONSTRUCTION DETAILS

Casing diameter 5" Length of casing 60'

Type of screen — Length of screen —

Type of pump 1/2 hp Webtrol

Capacity of pump 10 G.P.M.

Depth of pump setting 60'

Date of completion 11-19-85

BAILING OR PUMPING TEST
(specify one by circling)

Test rate 15 gpm Duration of test 1 hrs

Drawdown 0 ft Date 11-19-85

Static level (depth to water) 30' ft

Quality (clear, cloudy, taste, odor) Clear

Pump installed by Kern Drilling

WELL LOG*

Formations: sandstone, shale, limestone, gravel, clay	From	To
Top Soil	0 ft	2 ft
Yellow Clay	2	10
Blue Clay	10	60
Shale	60	70

SKETCH SHOWING LOCATION

Locate in reference to numbered state highways, street intersections, county roads, etc.



DRILLING FIRM Kern & Son DATE 11-19 85

ADDRESS Mt. Vernon, Ohio SIGNED Werly F. Kern

*If additional space is needed to complete well log, use next consecutive numbered form.

Roberts Rd (46)

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224