

WELL LOG AND DRILLING REPORT

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

629220

COUNTY MIAMI TOWNSHIP BROWN SECTION OF TOWNSHIP _____
OWNER WILLIE CONN ADDRESS 2162 ELM TREE RD. ST. PARIS
LOCATION OF PROPERTY 8075 LENA PALESTINE RD. LENA OH.

CONSTRUCTION DETAILS

Casing diameter 5 5/8 Length of casing 140
Type of screen - Length of screen -
Type of pump -
Capacity of pump -
Depth of pump setting -
Date of completion -

BAILING OR PUMPING TEST

(specify one by circling)

Test rate 28 gpm Duration of test BAILING hrs
Drawdown 10' ft Date 6-13-86
Static level (depth to water) 24' ft
Quality (clear, cloudy, taste, odor) CLEAR
Pump installed by OTERS.

WELL LOG*

Formations: sandstone, shale,
limestone, gravel, clay


From

To

TOP SOIL	0 ft	3 ft
YELLOW CLAY	3	12
HARD PAN	12	30
WATER GRAVEL	30	40
HARD PAN	40	104
WATER SAND	104	106
HARD PAN	106	138
WATER GRAVEL	138	140
HARD PAN.	140	

SKETCH SHOWING LOCATION

Locate in reference to numbered
state highways, street intersections, county roads, etc.



DRILLING FIRM Ray Nickman Well Drilling
ADDRESS 920 EVANSTON RD.

DATE 6-14-86
SIGNED Jerry Thonett (Driller)

*If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224