

WELL LOG AND DRILLING REPORT

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

629662
PERMIT 14396
REG.# 1107

6a
✓

COUNTY COSHOCTON TOWNSHIP PERRY SECTION OF TOWNSHIP 18

OWNER JOHN WILSON ADDRESS RT. 1 WALHONDING

LOCATION OF PROPERTY CROSS BRIDGE ON 383B TURN R. IN DRIVE

CONSTRUCTION DETAILS

Casing diameter 5 1/2 Length of casing 32
Type of screen NONE Length of screen _____
Type of pump NA
Capacity of pump _____
Depth of pump setting _____
Date of completion _____

BAILING OR PUMPING TEST

(specify one by circling)

Test rate 30 gpm Duration of test 2 hrs
Drawdown 4 ft Date 6-29-85
Static level (depth to water) 32' ft
Quality (clear, cloudy, taste, odor) CLEAR
NO ODDOR
Pump installed by NA

WELL LOG*

Formations: sandstone, shale,
limestone, gravel, clay


From

To

TOP SOIL + SHALE	0 ft	17 ft
SAND ROCK	17	21
GRAY SHALE	21	45
1. SAND ROCK	45	52
1. SHALE	52	54

SKETCH SHOWING LOCATION

Locate in reference to numbered
state highways, street intersections, county roads, etc.



DRILLING FIRM CARLE SHOEMAKER

DATE 7-24-85

ADDRESS 918 LIC. VAL RD FRAZEEBURG

SIGNED Carl E. Shoemaker

*If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224 21