

CES *New Well.* 629943

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

COUNTY MAHONING TOWNSHIP GOSHEN SECTION OF TOWNSHIP _____
OWNER DOVNA MAC HONIE ADDRESS 10954 SEACRIST ROAD
LOCATION OF PROPERTY 10954 SEACRIST ROAD BELOIT OH 44609

CONSTRUCTION DETAILS

BAILING OR ~~PUMP~~ TEST (specify one by circling)

Casing diameter 6" Length of casing 36
 Type of screen _____ Length of screen _____
 Type of pump 1/2 H.P. SUB
 Capacity of pump 10 GPM
 Depth of pump setting 74 FT.
 Date of completion 12-22-92

Test rate 10 gpm Duration of test 15 min hrs
 Drawdown 5 ft Date _____
 Static level (depth to water) 20 ft
 Quality (clear, cloudy, taste, odor) _____
 Pump installed by DRILLER

WELL LOG*

SKETCH SHOWING LOCATION

Formations: sandstone, shale,
limestone, gravel, clay

From

To

Formations: sandstone, shale, limestone, gravel, clay	From	To
GRAVEL	0 ft	10 ft
BLUE SHALE	10	36
FIRM SHALE & SAND	36	84
STONE LAYERS		

Locate in reference to numbered
state highways, street intersections, county roads, etc.

N

W

E

WELL X

MIDDLETON RD

SEACHRIST RD

S

Old Well was filled in
and abandoned. Same
property, only closer to
trailer (this well)
per note from drilled
1-20-93 303A

APPROVAL STAMP

DEPT. NAT. RESOURCES
DIV. OF WATER

DRILLING FIRM HAMPSON DRILLING
ADDRESS 1558 STATE BLVD

DATE 1-15-93
SIGNED William D. Thompson

*If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224