

# WELL LOG AND DRILLING REPORT

NO CARBON PAPER  
NECESSARY -  
SELF-TRANSCRIBING

State of Ohio  
DEPARTMENT OF NATURAL RESOURCES  
Division of Water  
Fountain Square  
Columbus, Ohio 43224

630615

2053

COUNTY Clinton TOWNSHIP Union SECTION OF TOWNSHIP \_\_\_\_\_  
OWNER Ronald Rudolph ADDRESS West Chiles Road  
LOCATION OF PROPERTY SR 134 North 1 mile out of civil

## CONSTRUCTION DETAILS

Casing diameter 5.5 Length of casing 65  
Type of screen \_\_\_\_\_ Length of screen \_\_\_\_\_  
Type of pump \_\_\_\_\_  
Capacity of pump \_\_\_\_\_  
Depth of pump setting \_\_\_\_\_  
Date of completion \_\_\_\_\_

## BAILING OR PUMPING TEST

(specify one by circling)

Test rate 5 gpm Duration of test 3 hrs  
Drawdown 40 ft Date May 10-87  
Static level (depth to water) 30' ft  
Quality (clear cloudy taste, odor) \_\_\_\_\_  
Pump installed by \_\_\_\_\_

## WELL LOG\*

Formations: sandstone, shale,  
limestone, gravel, clay

From

To

|               |      |       |
|---------------|------|-------|
| Clay          | 0 ft | 60 ft |
| Soft Shale    | 60   | 65    |
| Hard Shale    | 65   | 80    |
| Limestone     | 80   | 87    |
| Depth of well | 87   |       |

## SKETCH SHOWING LOCATION

Locate in reference to numbered  
state highways, street intersections, county roads, etc.

New House <sup>N</sup>

1341 N

W 1 Mile on Right E  
on 134

S

well

civil

DRILLING FIRM Clinton Well Drilling

DATE May 20-87

ADDRESS SR 134 S State 134

SIGNED John Hester

\*If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224

119