

WELL LOG AND DRILLING REPORT

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

632024

COUNTY Licking TOWNSHIP Licking SECTION OF TOWNSHIP _____
OWNER Jim and Patti McCoy ADDRESS 52 MARKLAN Rd., NEWARK, OH
LOCATION OF PROPERTY 1 mi E off of ST Rt #13 - NEWARK, OH

CONSTRUCTION DETAILS

Casing diameter 5" Length of casing 92 Ft
Type of screen N/A Length of screen -
Type of pump WEBTROL 1/2 H.P.
Capacity of pump 10 gpm
Depth of pump setting 80 Ft
Date of completion 9.30-85

BAILING OR PUMPING TEST

(specify one by circling)

Test rate 12 gpm Duration of test 8 hrs
Drawdown 7 ft Date 9-30-85
Static level (depth to water) 28 ft
Quality (clear, cloudy, taste, odor) Cloudy -
HARD TASTE
Pump installed by M & M

WELL LOG*

Formations: sandstone, shale,
limestone, gravel, clay


From

To

SAND AND GRAVEL 0 ft 92 ft

SKETCH SHOWING LOCATION

Locate in reference to numbered
state highways, street intersections, county roads, etc.



DRILLING FIRM M & M WATERWELL
ADDRESS 7080 HERGES LN., FAZ. O

DATE Nov 13, 1985
SIGNED Richard K. Moir

*If additional space is needed to complete well log, use next consecutive numbered form.

MARKLAN SRVA

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224