

WELL LOG AND DRILLING REPORT

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

632762

COUNTY Clinton TOWNSHIP Wayne SECTION OF TOWNSHIP _____
OWNER Darrell Woodruff ADDRESS (4467) St Rt 729 SW Sabon
LOCATION OF PROPERTY Same

CONSTRUCTION DETAILS

Casing diameter 6" OD Length of casing 33'-6"
Type of screen _____ Length of screen _____
Type of pump _____
Capacity of pump _____
Depth of pump setting _____
Date of completion _____

BAILING OR PUMPING TEST


(specify one by circling)

Test rate 30 gpm Duration of test 4 hrs
Drawdown 2 ft Date Aug 19 1987
Static level (depth to water) 8 ft
Quality (clear, cloudy, taste, odor) Clear
Pump installed by Self

WELL LOG*

Formations: sandstone, shale, limestone, gravel, clay	From	To
<u>clay</u>	0 ft	20 ft
<u>sand</u>	20	25
<u>hard pan</u>	25	30
<u>limestone</u>	30	45

SKETCH SHOWING LOCATION



DRILLING FIRM Shurtzwell Drilling

ADDRESS 4918 - U.S. - 12 - SW

DATE Aug 20 1987

SIGNED [Signature]

*If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224