

WELL LOG AND DRILLING REPORT

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

636546

COUNTY Clinton TOWNSHIP Clark SECTION OF TOWNSHIP _____
OWNER Chad Bailey ADDRESS Farmers Rd. New Vienna, 10
LOCATION OF PROPERTY Farmers Rd. - 1/2 mile south of St. Rt. 350

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST (specify one by circling)

Casing diameter <u>6</u> Length of casing <u>33</u>	Test rate <u>8</u> gpm Duration of test <u>2</u> hrs
Type of screen _____ Length of screen _____	Drawdown <u>3</u> ft Date <u>12/1/88</u>
Type of pump _____	Static level (depth to water) <u>13</u> ft
Capacity of pump _____	Quality (clear, cloudy, taste, odor) <u>clear</u>
Depth of pump setting _____	Pump installed by _____
Date of completion _____	

WELL LOG*

SKETCH SHOWING LOCATION

Formations: sandstone, shale,
limestone, gravel, clay


From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

Clay	0 ft	31 ft
Gravel	31	33

Water 33'



DRILLING FIRM

DATE

ADDRESS

SIGNED

*If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224