

WELL LOG AND DRILLING REPORT

NO CARBON PAPER
NECESSARY-
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

636840

COUNTY Sandusky TOWNSHIP Green Creek SECTION OF TOWNSHIP Seven (7)
OWNER Dennis & Stacy ADDRESS 9000 N. CR 51, Green Springs, OH
LOCATION OF PROPERTY 2902 E. Cole Rd (Rear) Fremont, OH 43420

CONSTRUCTION DETAILS

Casing diameter 8" Length of casing 97'
Type of screen — Length of screen —
Type of pump —
Capacity of pump —
Depth of pump setting —
Date of completion —

BAILING OR PUMPING TEST

(specify one by circling)


Test rate 300 gpm Duration of test 4 hrs
Drawdown — ft Date April 16, 1989
Static level (depth to water) 18 ft
Quality (clear, cloudy, taste, odor) Clear
Pump installed by —

WELL LOG*

Formations: sandstone, shale, limestone, gravel, clay	From	To
<u>soft shale</u>	<u>0 ft</u>	<u>90 ft</u>
<u>limestone</u>	<u>90'</u>	<u>106'</u>
<u>12 1/4" hole</u>		<u>97'</u>
<u>New 8 5/8" casing at</u>	<u>97'</u>	
<u>Cemented 18 sacks</u>		
<u>of cement to surface</u>		
<u>water</u>		<u>100'</u>

SKETCH SHOWING LOCATION

Locate in reference to numbered
state highways, street intersections, county roads, etc.



DRILLING FIRM Spencer Drilling Inc. ^{#255} DATE April 16, 1989
ADDRESS Venue, OH SIGNED John B. Harris

*If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224