

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

COUNTY Jackson TOWNSHIP Jackson SECTION OF TOWNSHIP
OWNER Wetzel Dempsey ADDRESS 265 Wills Rd. Bay Co.
LOCATION OF PROPERTY 265 Wills Rd. 1 mile east of Bay Street Rd.

CONSTRUCTION DETAILS	BAILING OR PUMPING TEST

Casing diameter 6" Length of casing 25'
Type of screen none Length of screen _____
Type of pump _____
Capacity of pump _____
Depth of pump setting _____
Date of completion _____

BAILING OR PUMPING TEST
(specify one by circling)

Test rate 1 gpm Duration of test 24 hrs
Drawdown dry ft Date 5/17/88
Static level (depth to water) 85' ft
Quality (clear, cloudy, taste, odor) Clear
Pump installed by unknown

SKETCH SHOWING LOCATION

Formations: sandstone, shale,
limestone, gravel, clay

From

To

Top Soil	0 ft	1 ft
Sandy clay	1	18
Sand stone	18	95
Blue shale	95	130
Sand stone	130	160

Locate in reference to numbered
state highways, street intersections, county roads, etc.

N

A hand-drawn sketch showing a well location. A vertical line on the left is labeled "Bay" and "road" with an arrow pointing down. A horizontal line on the right is labeled "willow" and "well" with an "X" mark. A north arrow "N" is at the top.

Water at 95 FT. W. 57th & Boylston E

DRILLING FIRM

DRILLING FIRM Coffey well drillers DATE 5/1/88

ADDRESS

ADDRESS 676 Brixton Corners

SIGNED

SIGNED William C. Coffey
 secutive numbered form.

If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224