

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

COUNTY Franklin TOWNSHIP Liberty SECTION OF TOWNSHIP _____
OWNER Jim Keller ADDRESS 2440 Tibbels Hill Rd.
LOCATION OF PROPERTY 1/2 way between Hanes Rd & Rt 193

CONSTRUCTION DETAILS			BAILING OR PUMPING TEST (specify one by circling)	
Casing diameter <u>6 x 4 1/2" liner</u>	Length of casing <u>47-160</u>		Test rate <u>12</u> gpm	Duration of test _____ hrs
Type of screen _____	Length of screen _____		Drawdown _____ ft	Date _____
Type of pump _____			Static level (depth to water) <u>70</u> ft	
Capacity of pump _____			Quality (clear, cloudy, taste, odor) _____	
Depth of pump setting _____				
Date of completion _____			Pump installed by _____	
WELL LOG*			SKETCH SHOWING LOCATION	
Formations: sandstone, shale, limestone, gravel, clay	From	To	Locate in reference to numbered state highways, street intersections, county roads, etc.	
<u>Surface</u>	<u>0 ft</u>	<u>47 ft</u>	N W S E	
<u>Coal mat (Black slate coal & fire clay) (caving in)</u>	<u>47</u>	<u>120</u>		
<u>shale</u>	<u>120</u>	<u>143</u>		
<u>sand rock</u>	<u>143</u>	<u>162</u>		
<u>Set shale trap at 100 ft</u>				

DATE 4/26/83

SIGNED Harold Foltz

*If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224