

NO CARBON PAPER
NECESSARY~
SELF-TRANSCRIBING

641195
Permit # 47790

COUNTY Muskingum TOWNSHIP Cass SECTION OF TOWNSHIP 4
OWNER Rosemary Zack ADDRESS 2850 N. Maple Ave Zanesville Ohio
LOCATION OF PROPERTY R.F.D. #1 Lockman Lane 43701

CONSTRUCTION DETAILS		BAILING OR PUMPING TEST (specify one by circling)	
Casing diameter <u>6" I.D.</u>	Length of casing <u>44'</u>	Test rate <u>25+</u> gpm	Duration of test <u>2</u> hrs
Type of screen _____	Length of screen _____	Drawdown <u>25</u> ft	Date <u>7/15/87</u>
Type of pump <u>Submersible</u>		Static level (depth to water) <u>41'</u>	ft
Capacity of pump <u>1/2 Hp</u>		Quality (clear, cloudy, taste, odor) <u>Clear</u>	
Depth of pump setting <u>81'</u>			
Date of completion <u>7/15/87</u>		Pump installed by <u>Speedy Water Well Drilling</u>	

[illegible]

DRILLING FIRM Speedy Water Well Drilling

ADDRESS 3880 Ash Meadows Blvd
Zanesville, Ohio

DATE 7/18/82

SIGNED: Glenn T. Speck
Continuation of FD-302 (Use separate numbered form.)

* If additional space is needed to complete work log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224