

NO CARBON PAPER
NECESSARY-
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

COUNTY Montgomery TOWNSHIP PERRY SECTION OF TOWNSHIP _____
OWNER ERNEST C. GERHART ADDRESS 5236 HECKATHORN RD BROOKVILLE OH
LOCATION OF PROPERTY 5320 HECKATHORN RD BROOKVILLE, OHIO

CONSTRUCTION DETAILS

BAILING OR PUMPING TEST

(specify one by circling)

Casing diameter 6" Length of casing 53'
 Type of screen — Length of screen —
 Type of pump 1/2 H.P. SUB
 Capacity of pump 8 GPM
 Depth of pump setting 40'
 Date of completion WELL 9-29-95

Test rate 15 gpm Duration of test 3 hrs
 Drawdown 7 ft Date 9-29-95
 Static level (depth to water) 15' ft
 Quality (clear, cloudy, taste, odor) CLEAR
 Pump installed by CATTRELL PLBC

WELL LOG*

SKETCH SHOWING LOCATION

Formations: sandstone, shale,
limestone, gravel, clay

From

To

Locate in reference to numbered
state highways, street intersections, county roads, etc.

Soil

0 ft

2 ft

Clay

2

52

Yellow lime seam

52

53-5'

Clay

53-5

—

N

WELL

DDD

SUB DIVISION

Hickory Rd

W

E

S

RECEIVED

2005-11-13

DRILLING FROM *1000* **CO**

DATE 10-2-73

ADDRESS 1130 E. Main St

SIGNED H. J. Simon

*If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224