

WELL LOG AND DRILLING REPORT

NO CARBON PAPER
NECESSARY -
SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

646300

COUNTY MONTGOMERY TOWNSHIP PERRY SECTION OF TOWNSHIP _____
OWNER George A. White ADDRESS 1545 N. CLAYTON RD Brookville
LOCATION OF PROPERTY 1/2 mi. N of OLD DAYTON RD W. side

CONSTRUCTION DETAILS

Casing diameter 6" Length of casing 152'
Type of screen — Length of screen —
Type of pump 1/3 HP SUB.
Capacity of pump 7 G.P.M.
Depth of pump setting 75'
Date of completion 12-11-96

BAILING OR PUMPING TEST (specify one by circling)


Test rate 75 gpm Duration of test 6 hrs
Drawdown 3 ft Date 12-10-96
Static level (depth to water) 47' ft
Quality (clear, cloudy, taste, odor) clear
Pump installed by D.C. DAINES

WELL LOG*

Formations: sandstone, shale, limestone, gravel, clay	From	To
<u>Soil</u>	<u>0 ft</u>	<u>2 ft</u>
<u>Gravelly Hard pan</u>	<u>2</u>	<u>74</u>
<u>Fine SAND + Quick SAND</u>	<u>74</u>	<u>78</u>
<u>Gravelly Hard pan</u>	<u>78</u>	<u>98</u>
<u>Water SAND + fine SAND</u>	<u>98</u>	<u>118</u>
<u>Coarse Gravel + Quick SAND</u>	<u>118</u>	<u>123</u>
<u>Water SAND + Quick SAND</u>	<u>123</u>	<u>147</u>
<u>Hard PAN</u>	<u>147</u>	<u>149</u>
<u>Quick SAND</u>	<u>149</u>	<u>150</u>
<u>Coarse Gravel + Water SAND</u>		
<u>SAND</u>	<u>150</u>	<u>152</u>

SKETCH SHOWING LOCATION

Locate in reference to numbered
state highways, street intersections, county roads, etc.



DRILLING FIRM D.C. DAINES Co.
ADDRESS 1130 E. MAIN ST T. TOWNSHIP

DATE 12-12-96
SIGNED Phil Daines

*If additional space is needed to complete well log, use next consecutive numbered form.

ORIGINAL COPY - ODNR, DIVISION OF WATER, FOUNTAIN SQ., COLS., OHIO 43224