WELL LOG AND DRILLING REPORT

NO CARBON PAPER NECESSARY – SELF-TRANSCRIBING

State of Ohio
DEPARTMENT OF NATURAL RESOURCES
Division of Water
Fountain Square
Columbus, Ohio 43224

648008

COUNTY LUCAS TOWNSHIP SYLVANIA SECTION OF TOWNSHIP #3

OWNER TOLEDO MEMORIAL PARK & MAUSOLEUM ADDRESS 6382 MONROE ST TOLEDO, OHIO

LOCATION OF PROPERTY TOLEDO MEMORIAL PARK & MASUSOLEUM TOLEDO, OHIO

CONSTRUCTION DETAILS

Casing diameter 7" Length of casing 26'

Type of screen NONE Length of screen

Type of pump Goulds (Lowora)/Franklin Motor

Capacity of pump 5 H.P./Single Phase/230 Volt

Depth of pump setting 95'

Date of completion DRILLING COMPLETED – SEPT. 15, 1988 PUMP INSTALLED 10/7/88

BAILING OR PUMPING TEST
(specify one by circling)

Test rate _____ gpm Duration of test _____ hrs

Drawdown _____ ft Date _____

Static level (depth to water) 25 ft

Quality (clear, cloudy, taste, odor) _____

Pump installed by _____

WELL LOG*

Formations: sandstone, shale, limestone, gravel, clay	From	To
BROWN CLAY	0 ft	5 ft
FRACTURED ROCK	5	8
GRAY LIME STONE	8	9
BROWN LIME STONE	9	15
GRAY LIME STONE	15	20
WHITE LIME STONE	20	40
GRAY LIME STONE	40	50
BROWN WITH GRAY STREAKS	50	60
SOFT BROWN LIME STONE	60	70
GRAY LIME STONE	70	105
BROWN LIME STONE	105	110
GRAY LIME STONE	110	140

SKETCH SHOWING LOCATION

Locate in reference to numbered state highways, street intersections, county roads, etc.



DRILLING FIRM Dunbar-Stark Drilling Inc.

ADDRESS 2997 Treat Hwy., Adrian, Mi 49221

DATE 10-8-88

SIGNED [redacted]